



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 13/06/2025

Area: WT

Equipment	Job
OT 4	200 W LED fitting replaced at out haul side
CP 1 to 4	communication problem ,LAN cable replaced 26 mtrs
OP 3	panel and motor side ppm done
OP 3,5 and 8	after rake maintenance done