



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 19/11/2025

Area: OHP

Equipment	Job
wbr-2 on co-25	It m2 motor is checked and restored in circuit.
brc-5 on co-32	estop near operator cabin guardis provided and cjb's tightness is ensured.
co-32 h/e hoist	ppm is done
tbs- on co-22 ; co-22,32	motor and panels ppm is done
brc-3 shifting	shifted from co-34 to 33m
tt-4	zss module, probe old ones recovered.
co-18,76r,3b	motor and panel ppm is done
co-69,70,37a,36a,33a,31a,32a	chute vibrators inspection is done
co-8a,38a	safety devices ppm is done; co-8a pull chord reset done and restored in circuit.
co-68	motor and panel side ppm is done
locp-2 rsco-2a level and stair case, crusher areas	illumination is improved.
cr-1a,2a,3a	hydraulic and lubrication power packs maintenance is done.
co-16a,16b	field devices ppm is done ; 16a h/e and 16b h/e illumination is improved
co-26	motor winding side lug damaged, replaced and observed currents.