



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 24/12/2025

Area: WT

Equipment	Job
OT 4	Motor 1 removed for mechanical job and placed again after clarence and tested
OP 6	Panel and Motor side ppm done,D3 and D6 lugs replaced one in each TB
OP 1	Anti collision sensor connected after attaching dummy wagons and tested
OP 1,2,3,5 and 7	After rake maintenance done