



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 26/01/2026

Shift: B

Incharge(s): Nagendra Midde

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------------------|--------------------|------------|----------|----------|---------|
| 1 | OHP | VS1A | OLR ACTED | RESET | 20:30:00 | 20:40:00 | |
| 2 | OHP | CO 16A | BRS MODULE PROBLEM | BYPASSED | 16:30:00 | 17:00:00 | |
| 3 | OHP | WBR ON CO 26 | B/W MPCB TRIP | MADE IT ON | 21:50:00 | 22:00:00 | |
| 4 | CHP | CC 19 | OLR ACTED | RESET | 16:00:00 | 16:10:00 | |
| 5 | CHP | CC 219 ZSS | MODULE PROBLEM | REPLACED | 16:30:00 | 17:00:00 | |
| 6 | CHP | CC 32 | OLR ACTED | RESET | 15:45:00 | 15:55:00 | |
| 7 | CHP | SCR 4 ON CC 31 SLEW | OLR ACTED | RESET | 15:55:00 | 16:10:00 | |
| 8 | CHP | SCR 6 ON CC 39 | B/C OLR ACTED | RESET | 17:05:00 | 17:15:00 | |
| 9 | CHP | CC 43 | OLR ACTED | RESET | 19:25:00 | 19:30:00 | |
| 10 | CHP | CC 125 | OLR ACTED | RESET | 21:50:00 | 21:55:00 | |
| 11 | WT | OP 10 | DRIVE 6 TRIP | RESET | 18:00:00 | 18:15:00 | |
| 12 | WT | CP 1 | C CLAMP DAMAGED | REPLACED | 16:00:00 | 16:15:00 | |