



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 17/11/2025

Shift: B

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 11(C)	olr acted	reset	19:10:00	19:20:00	
2	OHP	RSCO 10 A(B)	olr acted	reset	16:00:00	16:10:00	
3	OHP	brc on co 32	b/w 1 not running, 24 v high glass fuse blown	fuse replaced	17:10:00	17:45:00	
4	CHP	CC 38 SCR6	LT not working, drive tripped jamming	reset and informed operation	14:50:00	15:00:00	3 times, fault code 30002
5	CHP	CC 45	olr acted	reset	17:10:00	17:25:00	
6	CHP	CC 112 SCR8	luff not working, oil leaked, hose pipe damaged	informed mech and operation	17:20:00	17:40:00	
7	CHP	CC 203	olr acted	reset	18:50:00	19:00:00	
8	CHP	CC 54	trips due to overload 9 times	reset	15:34:00	19:36:00	
9	CHP	CC 51 A	motor tripped due to ol	reset	15:57:00	16:03:00	
10	CHP	CC 131	motor tripped due to OL 3 times	reset	16:04:00	21:46:00	
11	WT	CO 3(B)	mpcb tripped	made on	19:00:00	19:05:00	
12	WT	OT 5	D2 trips in spd fbk fault	reset	15:00:00	15:06:00	