



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 16/11/2025

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	RSCO 10A	OLR ACTED	RESET	04:40:00 23:30:00	04:55:00 23:50:00	
2	OHP	CO3	OLR ACTED	RESET	04:30:00	04:40:00	
3	OHP	CO 26	OLR ACTED	RESET	00:00:00	00:10:00	
4	OHP	BRC ON CO 30	B/W 2 OLR ACTED	RESET	01:25:00	01:35:00	
5	OHP	BRC ON CO 34 LT	PCRD O/T ACTED	RELEASED	05:00:00	05:20:00	
6	OHP	VS1A	OLR ACTED	RESET	05:40:00	05:50:00	
7	OHP	CR 2A LUB PUMP NOT RUNNING	RETURN FLOW OIL INDICATION ACTED,	FAULT RESET THEN OK	04:40:00	04:55:00	
8	CHP	CC 45	OLR ACTED	RESET	02:55:00	03:05:00	
9	CHP	SCR 2 ON CC 39	PCRD O/T ACTED	RESLEASED	01:55:00	02:10:00	
10	CHP	CC 131	OLR ACTED	RESET	01:45:00 03:30:00 23:15:00	01:50:00 03:35:00 23:20:00	
11	CHP	CC 51	FEEDING CON MPD ACTED	RESET	23:30:00	23:40:00	
12	CHP	CC 54	OLR ACTED	RESET	22:45:00	22:50:00	
13	CHP	CC 117	OLR ACTED	RESET	01:00:00	01:15:00	