



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 12/02/2026

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 17A RED	CONTROL FUSE BLOWN IN CJB	REPLACED THEN OK	21:30:00	21:45:00	
2	CHP	SCR 4 ON CC 31 SIGNAL MISSING	ETHERNET CABLE CONNECTIONS TIGHTENED	THEN OK	16:45:00	17:15:00	
3	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	15:00:00	22:00:00	12 TIMES