



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 26/11/2025

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR on CO-26	Reported LT not taking place	Checked and found drive emergency push button contact broken.Bypassed and Lt tested okay.PCRD overtension released	20:30:00	20:50:00	
2	OHP	BF-1A	Reported ZSS acting	Wrong complaint	19:20:00	19:30:00	
3	OHP	Co-34	Reported tripped	OLR acted.Reset done	20:50:00	21:00:00	
4	OHP	TBS on CO-22	Reported B/C CJD signal missing	Checked and wires tightened and tested okay	14:00:00	14:30:00	
5	CHP	CC-105 SCr 10	Reported LT not taking place	PCRd overtension acted.Released and tested okay	17:10:00	17:40:00	
6	CHP	CC-112 S-3	Reported slewing not taking place	Drive tripped.Reset done	19:29:00	19:42:00	
7	CHP	Cc-58	Reported tripped	OLR acted.Reset done(3 times) due to H/E pulley jamming	17:15:00	17:35:00	
8	CHP	CC-58	Reported not healthy	Checked and found chute sensor acted due to jamming	14:47:00	15:06:00	Informed to operation
9	CHP	Cc-29	Reported ZSS acting	OLD joint insulation damaged.Fresh joint made	15:30:00	16:00:00	