



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 15/08/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS on co 23	machine shifting to on 24	TBS shifted from co 23 to co 24	07:30:00	09:00:00	
2	OHP	CO 29	olr acted	reset	09:15:00	09:20:00	
3	OHP	TBS on CO 24	left boom luff not taking place, olr acted	reset	10:10:00	10:25:00	
4	OHP	BRC on CO 31	BRS bypass in brs module in field	small holes and belt ofcentric due to this brs acted, fully checked electric ckt all ok brs resetting also	12:00:00	12:30:00	
5	CHP	CC 104 SCR 9	stacking mode not coming,signal missing	LT fwd done than ok	07:30:00	07:40:00	
6	CHP	CC 31	motor tripped in OLR	olr reset	10:00:00	10:10:00	
7	CHP	CC 38 SCR 6	b/c healthy stops due to signal missing	LT done than ok	10:30:00	10:40:00	
8	CHP	CC 51	thermal olr acted	reset	13:20:00	13:25:00	
9	IOSA	sco1a (c)	mpcb trips	made it on	11:30:00	11:35:00	