



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 27/12/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-77	TRIPPED ON OLR	RESET DONE	06:20:00	06:25:00	
2	OHP	VS-3	OLR ACTED	RESET DONE	07:20:00	07:25:00	
3	OHP	TIS ON CO-29	BELT STOPPING ON ZSS FOUND IRON PIECE STUCK UP	REMOVED THAN OK	10:45:00	10:55:00	
4	OHP	WOBR ON CO-6A	B/C AND LUFFING NOT WORKING DUE TO MATERIAL JAMMING	INFORMED TO OPERATION AND MECHANICAL	07:00:00	07:10:00	
5	CHP	CC-117	OLR ACTED	RESET DONE	11:10:00	11:20:00	
6	CHP	CC-33 SCR3	REPORTED B/C NOT RUNNING OLR ACTED	RESET DONE THAN OK	12:45:00	12:55:00	
7	CHP	CC-104 SCR-9	REPORTED B/C STOPPING FREQUENTLY CHECKED AND FOUND ZSS CAGE STUCK UP	TEMPORARY ZSS BYPASSED AND GIVEN CLEARANCE	12:15:00	12:30:00	ZSS CAGE AND PROBE REPLACED WITH NEW AT 1345HRS BYPASS REMOVED
8	WT	OT-1	DRIVE -1 PGF-1 FAULT TRIP	RESET DONE	07:20:00	07:30:00	