



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 07/07/2025

Area: CHP

| Equipment                | Job   |
|--------------------------|---|
| CC 116                   | Spare motor shifted to mixture building and coupling removed            |
| CC 126 Stair case        | Ckt problem rectified and improved lighting                             |
| SCR 9                    | Slew panel MCCB replaced with Siemens 160A MCCB and trial run was taken |
| CC 31,34                 | Drive chute sensor modification was done                                |
| CC 31 , R1               | PPM was done  |
| CC 111,126,SCR 1,5,8,S 3 | Running inspection was done   |