



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 05/10/2025

Incharge(s): Nagendra Midde

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|---|--|----------------------|----------------------|----------|
| 1 | OHP | co 29 | OLR ACTED | RESET | 14:30:00 15:30:00 | 14:40:00 15:40:00 | |
| 2 | OHP | CO 77 | OLR ACTED | RESET | 15:00:00 | 15:10:00 | |
| 3 | OHP | CO 32 BRC | ZSS INTERLOCK CAGE HIGH LOOSE CONNECTION | TIGHTENED | 16:20:00 | 16:25:00 | |
| 4 | OHP | TBS ON CO 7A | LEFT BOOM CONTROL TRIPPING DUE TO CABLE GOT CRUSHED WUTH BOOM | CABLE REJOINTED THEN OK | 16:30:00 | 18:00:00 | |
| 5 | OHP | RSCO 10A | OLR ACTED | RESET | 15:15:00 | 15:30:00 | |
| 6 | OHP | CC 114 | OLR ACTED | RESET | 21:40:00 | 21:50:00 | |
| 7 | OHP | CO 10 A | OLR ACTED | RESET | 15:00:00 19:00:00 | 15:10:00 19:10:00 | |
| 8 | OHP | VF1A | M1 POWER MPCB TRIPPED | RESET | 18:00:00 | 18:10:00 | |
| 9 | OHP | OP10 | BREAKER TRIPPED | MADE IT ON | 20:30:00 | 21:00:00 | |
| 10 | CHP | SCR2 ON CC 34 | B/C C/S ACTED | INFORMED TO OPRN | 19:45:00 | 20:20:00 | |
| 11 | CHP | CC51 | FEEDING CONVEYOR TRIPPED | RESET | 15:00:00 | 22:00:00 | 10 TIMES |
| 12 | WT | OP2 | D1 TRIPPED | RESET DONE | 16:00:00 | 16:15:00 | |
| 13 | WT | OP 10 | BREAKER TRIPPED IN PUSHER AND COMMUNICATION PROBLEM | BREAKER MADE ON AND POE POWER RECYCLED COMMUNICATION ESTABLISHED | 14:00:00 | 16:00:00 | |