



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 23/11/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29	TRIPPED ON OLR (2TIMES)	RESET DONE	09:20:00 10:20:00	09:25:00 10:30:00	
2	OHP	TBS ON CO-22	LT NOT TAKING PLACE FOUND TRACK JAMMING	INFORMED TO OPERATION	10:15:00	10:30:00	
3	OHP	CO-16	OLR ACTED	RESET DONE	12:40:00	12:50:00	
4	OHP	RSCO-2A (C/D)	REPORTED NOT MOVE F/D FOUND PUSH BUTTON WIRE LOOSE	WIRE TIGHT THAN OK	11:20:00	11:30:00	
5	CHP	CC-51	FEEDING CONVEYOR MPD TRIP (3TIMES)	RESET DONE	07:15:00 07:30:00 08:40:00	07:20:00 07:35:00 08:45:00	
6	CHP	CC-54	TRIPPED ON OLR	RESET DONE	13:30:00	13:35:00	
7	CHP	CC-131	TRIPPEDE ON OLR	RESET DONE	12:00:00	12:10:00	
8	CHP	CC-28	OLR ACTED	RESET DONE	10:10:00	10:20:00	
9	CHP	CC-29	OLA ACTED	RESET DONE	12:50:00	13:00:00	
10	CHP	CC-32 R-1	REPORTED B/C AND LUFFING NOT WORKING FOUND B/C TRIPPED ON OLR ,LUFFING AIR LOCK	OLR RESET DONE AND INFORMED TO MECHANICAL	09:20:00	10:00:00	
11	CHP	CC-39 SCR-2	REPORTED SLEW NOT WORKING 30DEGREE LIMIT ACTED	RELEASED	10:40:00	10:50:00	
12	CHP	CC-112 S-3	LT NOT TAKING PLACE FOUND DRIVE TRIP	RESET DONE THAN OK	11:00:00	11:10:00	
13	CHP	CC-125	TRIPPED ON OLR	RESET DONE	12:00:00	12:05:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/11/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	WT	OC-1A B/D	TRIPPED ON OLR (4TIMES)	RESET DONE	08:40:00 09:00:00 12:50:00 13:10:00	08:50:00 09:10:00 12:55:00 13:20:00	
15	WT	OT-1	DRIVE-2 TRIP PGF-1 FAULT	RESET DONE	10:00:00	10:10:00	
16	WT	SCO-1A (C/D)	TRIPPED ON OLR	RESET DONE	12:35:00	12:45:00	
17	WT	OP-4	REPORTED MOVE IN R/D ACB TRIP IN LC (3TIMES)	MADE ON	09:25:00 11:45:00 12:50:00	09:40:00 11:55:00 13:00:00	
18	IOSA	OC-7B	REPORTED STOPPING ONZSS FOUND BELT THROUGH CUT	IN FORMED TO OPERATION	07:30:00	07:45:00	