



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

#### ELECTRICAL SHIFT REPORT

Date: 25/07/2025

Shift: A

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WF 5	ZSS acted, probe sensor not working due to dust	sensor cleaned than ok	07:40:00	07:55:00	
2	OHP	VS 1A	olr acted	reset	13:25:00	13:30:00	
3	OHP	CO 32	not running, MCCB trips immediately after giving CMD	motor TB opens, megger done all value found Ok,, again cables terminated in motor Tb than given cmd all ok	07:45:00	08:25:00	
4	OHP	CO35	Electronic over load acted	Reset done	09:00:00	09:10:00	11.45am to 11.50am
5	CHP	CC 32 SCR5	LT not working, OT acted	OT released	09:35:00	09:45:00	
6	CHP	CC 104 SCR9	LT not working, OT acted	OT released	10:00:00	10:10:00	
7	CHP	CC 201	motor not running. D/E CJD acted due to jamming	informed operation	10:10:00	10:20:00	
8	CHP	CC 111 R1	ZSS acted, cage problem	ZSS cage replaced than ok	09:20:00	09:30:00	
9	CHP	CC54	Over load trip 3 times	Reset done	08:40:00	08:45:00	09.20am to 09.25am: 11.10am to 11.15am
10	CHP	CC117	Over load trip due to over load	Reset done	07:53:00	08:05:00	
11	CHP	CC113	Over load acted	Reset done	12:30:00	12:35:00	
12	CHP	CC51	ZSS acted due to return idlers damaged	Informed to mechanical after changing ZSS reset and clearance given	08:05:00	08:45:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 25/07/2025

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	CC17 belt drive	Over load acted	Reset done	07:15:00	07:20:00	
14	CHP	SCR1 on CC35	Slew not working found slew right limit acted	Limit released then ok	12:25:00	12:35:00	
15	WT	SCO 1A(c)	OLR acted	reset	06:30:00	06:40:00	
16	WT	OP8	no fwd movement, D6 trips in overload	reset	08:10:00	08:20:00	
17	WT	CO 3(B)	OLR acted	reset	08:45:00	08:55:00	
18	WT	CO3 carriage	over load trip	reset done	06:50:00	07:00:00	
19	IOSA	TBS	Lt not working found end limit acted	Released ok	11:30:00	11:50:00	No delay
20	IOSA	WOBR old	LT drive fault lv at normal speed 2 times	Reset done	13:20:00	13:30:00	01.55pm to 02.00pm