



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 28/12/2025

Shift: B

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29	Reported tripped	OLR acted.Reset done(2 times)	16:05:00 19:50:00	16:10:00 19:55:00	
2	OHP	VF-23	M-1 acted	Reset done	14:50:00	15:00:00	
3	OHP	BRC on CO-32	Lt not taking place	Drive-2 tripped.Reset done	15:50:00	16:00:00	
4	OHP	VF-23	M1 tripped	R-ph cut in motor TB.connected properly and tested okay	16:00:00	16:30:00	
5	OHP	CR-1	Reported showing running but physically motor not running	Voltage controller changed and connections checked and tested okay	14:00:00	19:00:00	
6	CHP	Cc-117	Reported tripped	OLR acted.Reset done	15:10:00	15:20:00	
7	CHP	CC-131	Reported tripped	OLR acted.Reset done	21:40:00	21:45:00	
8	WT	OT-1	Reported tripped	D-1 tripped on PGEF-1 fault.Reset done	20:15:00	20:20:00	
9	IOSA	OC-7B	Reported not healthy	Checked and found MPD failure.contact removed and tested okay	20:00:00	21:30:00	MPD to be changed
10	IOSA	BRC	CT Emergency limit acted	Normal limit handle adjustment done and tested okay	21:00:00	21:30:00	