



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 06/06/2025

Area: CHP

Equipment	Job
CC 222/223 gallery	Lighting ckt problems rectified and improved lighting
CC 27 ZSS	Module shifted to near zss cage and tested
CC 29,CC-29TT,109,110,33,SCR 4	PPM was done
SCR 6	Cable chamber material cleaning done
R 1	PCRD OT limit adjusted and kept in ckt
SCR 2	Reclaiming mode cage interlock provided