



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 18/09/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29	OLR ACTED (3TIMES)	RESET DONE	08:00:00 09:00:00 10:00:00	08:10:00 09:10:00 10:10:00	
2	OHP	WOBR ON CO-26	REPORTED SLEW NOT WORKING CHECKED OLR ACTED	RESET DONE (2TIMES)	08:15:00 11:45:00	08:30:00 12:00:00	
3	OHP	TT-3 ON BIPC-1	REPORTED POSITION INDICATION MISSING DUE TO MATERIAL JAMMING	OPERATION REQUIREMENT POSITION INDICATION BYPASSED IN I/O RACK	11:30:00	11:45:00	
4	OHP	CC-37 SCR-7	REPORTED SLEW NOT WORKING CHECKED AND FOUND OIL LOW LEVEL	INFORMED TO MECHANICAL	07:10:00	07:20:00	
5	CHP	CC-51	OLR ACTED	RESET DONE	09:40:00	09:45:00	
6	CHP	CC-40 S-1	LUFF NOT WORKING CHECKED MPCB TRIP	MADE ON	07:10:00	07:40:00	
7	CHP	CC-31 SCR-4	REPORTED SLEW NOT WORKING CHECKED AND FOUND POWER MCCB TRIP	MADE ON THAN OK	07:15:00	07:30:00	
8	CHP	CC-36 SCR-1	REPORTED PCRD CABLE FALLEN DOWN	PCRD CABLE PROPER LAYING WAS DONE	09:45:00	10:00:00	
9	WT	OT-1	DRIVE -1 TRIP	RESET DONE	12:20:00	12:25:00	
10	WT	OT3	d2 trips in encoder fault	reset	10:10:00	10:15:00	