



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 16/05/2025

Area: CHP

| Equipment | Job |
|---------------|--|
| CC 112, SCR 8 | PPM WAS DONE |
| RG Building | Lighting rectification done and 3 nos lamp fixtures provided |
| SCR 4 | LT Motor replaced and trial run was taken |
| JH C5 | LDB maintenance work done |
| JH C 15, C 16 | Hoist maintenance work done |