



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 28/05/2025

Shift: B

Incharge(s): Lal Singh

| Sl No | Area | Equipment    | Problem                                  | Action  | From                 | To                   | Remarks |
|-------|------|--------------|--|---|----------------------|----------------------|---------|
| 1     | OHP  | CO-29        | OLR ACTED                                | RESET DONE  | 14:10:00<br>19:20:00 | 14:15:00<br>19:30:00 |         |
| 2     | OHP  | CO-29        | TRIPPED ON SPP                           | RESET DONE AND TESTED .... CURRENTS CHECKED FOUND OK                          | 16:00:00             | 16:10:00             |         |
| 3     | OHP  | RSCO-10A     | TRIPPED ON OLR                           | RESET DONE  | 15:30:00             | 15:40:00             |         |
| 4     | OHP  | co-34        | TRIPPED ON OLR                           | RESET DONE  | 17:25:00             | 17:30:00             |         |
| 5     | OHP  | VS-2A        | CHUT SENSOR ACTING DUE TO STONES TUCHING | CHECKED CHUT SENSOR WORKING FINE  | 15:30:00             | 15:45:00             |         |
| 6     | CHP  | ALL MACHINES | COMMUNICATION PROBLEM                    | CCR MODEM REBOOT DONE   | 21:20:00             | 21:40:00             |         |
| 7     | CHP  | CC-27A       | CHUT SENSOR MODULE GLASS RELAY LOOSE     | FIXED PROPERLY  | 19:30:00             | 19:45:00             |         |
| 8     | CHP  | CC-41        | C/S SHOWING RED                          | CHUT SENSOR ALREADY IN SERIES WITH PB.... CHUT SENSOR BIT BYPASSED IN PROGRAM | 17:45:00             | 18:10:00             |         |
| 9     | CHP  | CC-54        | TRIPPED ON OLR                           | RESET DONE  | 14:05:00<br>14:55:00 | 14:10:00<br>15:00:00 |         |
| 10    | CHP  | CC-131       | TRIPPED ON OLR                           | RESET DONE  | 19:55:00             | 20:00:00             |         |
| 11    | CHP  | CC-113       | MECH BRS SWITCH PROBLEM                  | REPLACED  | 15:00:00             | 15:20:00             |         |
| 12    | WT   | OP-10        | ES PB ACTED                              | RELEASED  | 14:00:00             | 14:20:00             |         |