



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/05/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 35	OLR acted	reset it done	22:35:00	22:40:00	3 times
2	OHP	CO 29	OLR acted	reset	00:00:00	00:15:00	
3	OHP	CO 26	OLR acted	reset	00:00:00	00:15:00	
4	OHP	CO 34	OLR acted	reset	04:10:00	04:15:00	
5	OHP	CO 6a	brs not resetting,sensor problem	sensor adjusted properly	22:35:00	22:50:00	
6	OHP	CO 14 A	brs not resetting,reset button stucked up	reset button released	23:30:00	23:45:00	
7	OHP	BRC 32	B/C trips in OLR	reset	05:00:00	05:15:00	
8	CHP	CC 131	OLR acted	reset	03:15:00	03:20:00	
9	CHP	CC 52	ZSS acted,overload	clear load in local	01:45:00	01:50:00	
10	CHP	CC 112 SCR 8	BC not running,BSS acted	released it	22:25:00	22:40:00	
11	CHP	CC 32 SCR5	LT not working,under tension acted,pcrd guide problem	tension released informed mech	23:45:00	00:07:00	
12	CHP	CC 33 SCR4	LT not working inn remote mode,drive trips in SCF3 fault,in local LT ok,K1 relay not healthy	K! relay high given than remove after that ok	23:50:00	00:30:00	
13	CHP	CC 32	ZSS acted electrical all ok,belt tension problem	informed mech incharge	02:00:00	02:15:00	
14	CHP	CC 34 SCR 2	LT not taking place,vfd trips in ovrload	reset it done	02:00:00	02:15:00	
15	CHP	CC 105 scr 10	LUFF up not working,BC deck sheet full jamming	inform operation and mech,manually luffing up done than ok	03:40:00	04:10:00	
16	CHP	CC 125	OLR acted	reset it	04:55:00	05:05:00	



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/05/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
17	CHP	CC 107	ZSS acted, belt full load condition, belt slow movement	informed operation incharge	05:00:00	05:20:00	