



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 10/07/2025

Area: CHP

Equipment	Job
SCR-4,5	CCR communication healthy relays programming and testing done
CC-38	HT isolator maintenance done
CC-33,SCR-4	ppm done
Misc	Street light cables joint work done. ( CCR turn point to LC-18)
CM-19	control bus bar maintenance done
CC-33	Head end chute sensor, SCR-4 discharge chute sensor modification done using polymer sheets