



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 29/12/2025

Shift: C

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO9	OLR ACTED	RESET	23:45:00	23:55:00	
2	OHP	CO25	OLR ACTED	RESET	02:45:00	02:55:00	
3	OHP	WBR ON CO 25	SLEW DRIVE TRIPPED	RESET	04:30:00	04:45:00	
4	CHP	CC 51	FEEDING CONVEYOR OLR ACTED	RESET	23:30:00	02:10:00	6 TIMES
5	CHP	CC 131	OLR ACTED	RESET	03:50:00	03:55:00	
6	CHP	CC117	OLR ACTED	RESET	00:15:00	00:30:00	
7	CHP	CC 28 T/T F/G	OLR ACTED	RESET	02:30:00	02:40:00	
8	CHP	CC 28	OLR ACTED	RESET	05:45:00	05:55:00	
9	CHP	CC 39	OLR ACTED	RESET	00:45:00	00:50:00	
10	CHP	SCR 6 ON CC 39	B/C OLR ACTED	RESET	01:45:00	01:55:00	
11	CHP	SCR 6 ON CC 39 LT	DRIVE TRIPPED	RESET	02:00:00	02:05:00	
12	CHP	SCR 5 ON CC 32	B/C OLR ACTED	RESET	02:15:00	02:30:00	
13	CHP	SCR 7 ON 37 B/C	BELT SLIPPING	INFORMED TO OPRN	04:30:00	04:40:00	
14	WT	AF5	DRIVE TRIPPED	RESET	23:30:00	23:35:00	