



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/11/2025

Shift: B

Incharge(s): Amit Roy

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------|--|---|----------|----------|-----------------------|
| 1 | OHP | OM-10 | Reported all conveyors red | Checked and found control not there.MCB tripped in control transformer panel.Made on. | 15:00:00 | 15:10:00 | |
| 2 | OHP | CC125 | Reported tripped | OLR acted.Reset done(2 times) | 19:02:00 | 20:39:00 | |
| 3 | OHP | CO-77 | Reported tripped | OLR acted.Reset done | 18:35:00 | 18:40:00 | |
| 4 | OHP | BRC on CO-28 | Reported LT not taking place | Checked and found Drive tripping on earth fault due to M5 motor cable fault.Rectified | 17:40:00 | 18:00:00 | |
| 5 | OHP | CO-24 | Reported not running in local | Start button problem.Wire loose.Rectified | 20:00:00 | 20:10:00 | |
| 6 | OHP | Co-29 | Reported tripped | OLR acted.Reset done | 18:55:00 | 19:00:00 | |
| 7 | OHP | Co-33M | Reported tripped | OLR acted.Reset done | 19:20:00 | 19:25:00 | |
| 8 | CHP | CC-53 | Indication not coming to RG-3 | Sensor cleaned and tested okay | 19:35:00 | 19:45:00 | |
| 9 | CHP | CC-52 | Reported not running | Checked and found no drive position showing CCR.DOL mode bypassed in I/O rack and tested okay | 19:50:00 | 20:10:00 | |
| 10 | CHP | CC-24 | Reported ZSS acting | Cage bearing problem.Bypassed due to demand.Cage replaced after demand | 14:45:00 | 14:55:00 | Bypass removed |
| 11 | CHP | CC-28 | Reported TT not moving | MPCB tripped.Made on. | 17:30:00 | 17:40:00 | |
| 12 | CHP | CC28 | indications showing on CC-31 and cc-33 | Rectified | 18:00:00 | 18:06:00 | |
| 13 | CHP | CC105 | Chute sensor acted. | Jamming found | 16:40:00 | 17:00:00 | Informed to operation |
| 14 | CHP | CC 39 SCR-1 | LT reverse not working | joystick cable tightened and end limit released and tested okay | 17:05:00 | 17:53:00 | |
| 15 | CHP | CC-44 | reported tripped | OLR acted.Reset done(4 times) | 18:30:00 | 19:55:00 | |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/11/2025

Incharge(s): Amit Roy

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------|------------------------------|--|----------------------|----------------------|---------|
| 16 | CHP | CC-32 R-1 | Luffing down not working | Contactor stuck.Made free | 19:20:00 | 19:35:00 | |
| 17 | CHP | CC-54 | Reported tripped | OLR acted.Reset done | 20:20:00 20:35:00 | 20:25:00 20:40:00 | |
| 18 | WT | OP-7 | Selection not coming to OT-4 | Checked and found MCB tripped in PLC panel of OT-4.Made on | 15:55:00 | 16:00:00 | |
| 19 | WT | CO-3 | Reported tripped | OLR acted.Reset done | 16:15:00 | 16:20:00 | |
| 20 | IOSA | BRC | B/W not rotating | OLR acted.Reset done | 21:35:00 | 21:45:00 | |