



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 25/10/2025

Incharge(s): Lal Singh

Shift: B

| Sl No | Area | Equipment    | Problem                                | Action   | From                 | To                   | Remarks   |
|-------|------|--------------|--|--|----------------------|----------------------|---|
| 1     | OHP  | co-26        | TRIPPED ON OLR                         | RESET DONE   | 14:20:00             | 14:30:00             |   |
| 2     | OHP  | BRC ON CO-31 | BC NOT RUNNING DUE TO CHU SENSOR ACTED | CLEANED THEN OK  | 15:30:00             | 15:45:00             |   |
| 3     | OHP  | CO-36A       | CHUT SENSOR ACTED                      | SENSOR CLEANED   | 20:50:00             | 21:10:00             |   |
| 4     | OHP  | CO-3A        | STOPPED ON ZSS BECAUSE OF BELT SLOWING | SPEED SETTING INCREASED IN ZSS MODULE ON OPERATION REQUEST | 18:00:00             | 18:20:00             |   |
| 5     | CHP  | CC-29 BD     | TRIPPED ON OLR                         | RESET DONE   | 17:30:00<br>20:00:00 | 17:35:00<br>20:10:00 |   |
| 6     | CHP  | CC-104 SCR9  | TUL CHUT SENSOR ACTING                 | CHUT JAMM .. INFORMED FOR CLEANING                         | 16:25:00             | 16:35:00             |   |
| 7     | CHP  | CC-45        | TRIPPED ON OLR                         | RESET DONE   | 16:00:00<br>17:15:00 | 16:10:00<br>17:25:00 |   |
| 8     | CHP  | CC-107       | TRIPPED DUE TO OLR                     | RESET DONE   | 19:50:00             | 20:00:00             |   |
| 9     | CHP  | CC-51        | MPD TRIP ( 3TIMES )                    | RESET DONE   | 16:25:00             | 18:50:00             | MPD MALF UNCTIONIN G TRIPPING IN UNDER CURRENT ... BYPASSED |
| 10    | CHP  | CC-51        | TRIPPED ON OLR 2 TIMES                 | RESET DONE   | 21:00:00             | 21:10:00             |   |
| 11    | CHP  | CC-54        | TRIPPED ON OLR                         | RESET DONE   | 18:16:00<br>18:25:00 | 18:20:00<br>18:30:00 |   |



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 25/10/2025

Incharge(s): Lal Singh

Shift: B

| Sl No | Area | Equipment | Problem        | Action                          | From     | To       | Remarks |
|-------|------|-----------|----------------|---------------------------------|----------|----------|---------|
| 12    | CHP  | CC-51A    | TRIPPED ON OLR | RESET DONE                      | 18:59:00 | 19:05:00 |         |
| 13    | WT   | OP-7      | NOT MOVING     | ES PRESSED IN CABIN ...RELEASED | 16:45:00 | 16:50:00 |         |