



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 16/06/2025

Area: OHP

Equipment	Job
LOCP-1	Crushers,VF's motor and panel PPM done
LOSP-1	ALL motors and panel PPM done
CO-5,1A	Sump pump maintenance done
CO-5	P/C checking is going on
TBS ON CO-5A	Brake timer replaced and tested okay
BRC on CO-32	CT limit switch replacement done and tested okay
BRC-4 on CO-34	BW-1 ZSS rectified and kept in line
WOBR on CO-29,CO-29	PPM done