



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 26/12/2025

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	OT3	DRIVE 2 PGF1 FAULT	RESET	05:35:00	05:40:00	
2	OHP	BRC ON CO 28 B/W1	OLR ACTED	RESET	22:22:00	22:30:00	
3	OHP	BRC ON CO 28 B/W1	GUIDE ROLLER PROBLEM	INFORMED TO MECH	23:45:00	00:00:00	
4	OHP	CO 25	OLR ACTED	RESET	00:35:00	00:45:00	
5	OHP	WBR ON CO 26	SLEW DRIVE TRIPPED	RESET	04:50:00	05:05:00	
6	OHP	CO 29	OLR ACTED	RESET	05:25:00	05:35:00	
7	OHP	VS 3A	OLR ACTED	RESET	05:45:00	05:55:00	
8	CHP	SCR 6 ON CC 39 LT	M2 TRIP DUE TO TRACK JAMMING	MADE IT ON	01:15:00	01:30:00	
9	CHP	CC 43	OLR ACTED	RESET	02:15:00	02:25:00	
10	CHP	CC 26	T/T LT MPCB TRIPPED	MADE IT ON	22:30:00	22:40:00	
11	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	23:30:00	05:40:00	13 TIMES
12	CHP	CC 54	OLR ACTED	RESET	02:40:00	02:45:00	