



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/02/2026

Shift: A

Incharge(s): K SANKARA RAO

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------|---|---|----------------------|----------------------|---------|
| 1 | OHP | CO-29 | REPORTED P/C NOT HEALTHY GLASS FUSE BLOWN DUE TO EARTH FAULT IN FIELD | FIELD WIRES REMOVED AND P/C BYPASSED IN CJB | 06:40:00 | 06:55:00 | |
| 2 | OHP | VF-19 | REPORTED NOT HEALTHY FOUND MPCB TRIP DUE TO R-PHASE RUBBED WITH GI PIPE | R-PHASE TAPPING WAS DONE THAN MPCB MADE ON OK | 10:00:00 | 10:20:00 | |
| 3 | OHP | CO-26 | OLR ACTED (2TIMES) | RESET DONE | 10:30:00 11:55:00 | 10:40:00 12:00:00 | |
| 4 | OHP | BRC ON CO-32 | B/W S NOT RUNNING OIL LOW LEVEL | INFORMED TO OPERATION | 10:30:00 | 10:40:00 | |
| 5 | CHP | CC-51 | MPD TRIP (2 TIMES) | RESET DONE | 07:00:00 08:20:00 | 07:05:00 08:25:00 | |
| 6 | CHP | CC-117 | OLR ACTED (2 TIMES) | RESET DONE | 09:00:00 09:50:00 | 09:10:00 10:00:00 | |
| 7 | CHP | CC-213 | OLR ACTED | RESET DONE | 07:30:00 | 07:40:00 | |
| 8 | CHP | CC-125 | OLR ACTED | RESET DONE | 09:00:00 | 09:05:00 | |
| 9 | CHP | CC-40 SCR-2 | LUFFING NOT WORKING OIL LOW LEVEL | INFORMED TO MECHANICAL | 11:30:00 | 11:45:00 | |
| 10 | CHP | CC-104 SCR-7 | REPORTED B/C STOPPING ZSS CAGE STUCK UP COAL PICK | REMOVED THAN OK | 12:50:00 | 13:00:00 | |
| 11 | CHP | CC-104 SCR-7 | SLEW LEFT NOT WORKING IN XMD SETTING PROBLEM | IN XMD MA SETTINGS CHANGED THAN OK | 08:40:00 | 09:00:00 | |
| 12 | CHP | CC-221 | REPORTED HEALTHY STOP DRIVE OUT PUT C-2 POWER CONTACTOR PROBLEM | POWER CONTACTOR BYPASSED | 11:40:00 | 12:00:00 | |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/02/2026

Shift: A

Incharge(s): K SANKARA RAO

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|--|--------------------------|----------|----------|---------|
| 13 | IOSA | BRC ON OC-15A | B/C STOPPING ON ZSS CAGE STUCK UP WITH STONE | STONE REMOVED THAN OK | 08:40:00 | 09:00:00 | |
| 14 | IOSA | OC-27A | BRS NOT RESET | SENSOR S CLEANED THAN OK | 11:05:00 | 11:20:00 | |