



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 07/05/2025

Area: CHP

Equipment	Job
CM 18, coal complex	Rooms cleaning done
CC 51	Lighting provided for belt changing job
CC 51	For over load alarm,MPD fixed and wiring done
CC 51A,109,110	PPM was done
CC 110	Mechanical BRS installed and kept in ckt
HT coupler Heaters	Inspected for heating of all couplers
SCR 2	For communication healthy , indication lamp provided in operator cabin
SCR 2	@ nos LT motors termination done ,coupled and trial run was taken