



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 27/06/2025

Area: CHP

Equipment	Job
CC-51 H/E road side hoist	ppm and up limit switch adjustment done and kept in circuit
LC-18	Dewatering Auto circuit probe cable replaced and auto mode checking done
CC-41	Motor CJB to panel cable gallery new control cable laid
SCR-9,SCR-3	New antenna installed
SCR-1	feed table zss module connection done and input bit programming done
Misc	STK-1 and SCR-1 interchanging done