



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 21/09/2025

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 20	BRS acted, transmitter not adjusted properly nut bolt loosened	properly adjusted than ok	00:25:00	00:33:00	to be checked in G shift
2	OHP	VS 1	olr acted, MPCB tripped	made it on	04:00:00	04:10:00	
3	OHP	CO 26	olr acted	reset	01:30:00	01:40:00	
4	CHP	CO 9	OLr acted due to overload on belt	reset	04:40:00	04:45:00	
5	CHP	CC 29 FLAP GATE	mpcb tripped	made it on	22:20:00	22:30:00	
6	CHP	CC 21 (B)	olr acted	reset	22:30:00	22:35:00	
7	CHP	CC 112 SCR8	BC mpr tripped	reset	01:21:00	01:33:00	
8	CHP	CC 36 SCR1	BW OLR acted	reset	01:55:00	02:05:00	
9	CHP	CC 34 SCR 2	slew not working, slew limit acted	limit released	03:25:00	03:40:00	
10	CHP	CC 108	OLR acted	reset it done	03:35:00	03:40:00	
11	CHP	CC 40	OLR acted	reset	04:25:00	04:35:00	
12	WT	OT 3	D1 tripped in encoder fault	reset	05:35:00	05:40:00	