



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 14/07/2025

Area: CHP

Equipment	Job
CC 41/42 spare	Motor prepared and shifted to JH 17
LC 15	Floor cleaning done
SCR 10	Boom conveyor control MCB replaced, field switches cables inspected and kept in ckt
CC 105, SCR 10	PPM was done
CCR	UPS batteries maintenance was done
LC 15 spare breaker	Charged supply to Quartzite crushing plant after terminating the cables
SCR 10	TUL chute sensor modification done