



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 31/07/2025

Area: OHP

| Equipment | Job |
|---|---|
| TBS ON CO 23, TBS ON CO 21 | RUNNIG INSPECTION DONE |
| BRC ON CO 34 | FUSED TBS PROVIDED FOR RTD |
| TBS ON CO 19, CO-19 | PPM COMPLETED |
| DE 21 Y PHASE LUGS | RECONNECTED PROPERLY |
| CO 1A | BRS KEPT IN CIRCUIT |
| CO 6 , | BRS KEPT IN CIRCUIT |
| CC-17 CC-24 | PPM BOTH PANEL SIDE AND MOTOR SIDE DONE |
| JH-14 , BPC-1, BPC-2, CO 27A, CO 30A | HOIST PPM DONE |
| CO 59,60, 61 | MOTOR GREASING DONE |
| LC-3 I/O RACK | MODIFICATION DONE |
| TBS ON CO-7 | SHIFTED TO CO-24 |