



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 21/08/2025

Shift: B

Incharge(s): Lal Singh

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------------|--|---|----------------------------------|----------------------------------|----------------------------|
| 1 | OHP | VS 2 | tripped in olr | reset | 16:20:00 | 16:30:00 | |
| 2 | OHP | wobr 29 | It not working,m4 olr acted | reset | 15:10:00 | 15:30:00 | |
| 3 | OHP | WOBR on co 29 | b/c olr acted | reset | 15:50:00 17:05:00 20:20:00 | 16:05:00 17:20:00 20:35:00 | |
| 4 | OHP | CO 29 | olr acted | reset | 16:40:00 | 16:50:00 | 2 times |
| 5 | OHP | BRC on co 30 | cabin side ct limit stucked | made released | 17:15:00 | 17:30:00 | |
| 6 | OHP | BRC on CO 30 | LT not taking place,drives in hands on mode | change to auto on | 18:00:00 | 18:15:00 | |
| 7 | OHP | CO 35 | olr acted | reset | 19:45:00 | 19:50:00 | |
| 8 | OHP | wobr on co 29 | B/C not running,bc on PUSH BUTTON BROKEN AND GOT EARTHED,control wires in control desk and in boom conveyor panel got burn | on push button shifted to bypass button,control wires replaced and tested | 21:20:00 | 22:20:00 | push button to be provided |
| 9 | CHP | CC 51 | olr acted | olr reset | 16:20:00 | 16:25:00 | |
| 10 | CHP | CC 114 | olr acted | reset | 19:59:00 | 20:05:00 | |
| 11 | CHP | co 11(c) | mpcb trips | made it on | 19:55:00 | 20:00:00 | |
| 12 | CHP | CC 14 | tripped in curt sp | reset it done | 18:10:00 | 18:20:00 | |
| 13 | CHP | CC 29 pos on cc 111 | wire loose in i/o rack | cable properly fixed | 21:15:00 | 21:30:00 | |
| 14 | CHP | CC 126 | cjd wire got cut | jointed | 15:20:00 | 15:45:00 | |
| 15 | CHP | CC33 scr 4 | LT not working OT acted | OT released | 16:15:00 | 16:25:00 | |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 21/08/2025

Incharge(s): Lal Singh

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------|------------------------------------|--------------------|----------|----------|---------|
| 16 | CHP | cc 104 scr 9 | slew not working,slew limit acted | limit released | 16:45:00 | 17:10:00 | |
| 17 | CHP | CC 32 SCR 5 | LT not working,OT acted | OT released | 17:00:00 | 17:20:00 | |
| 18 | CHP | CC 32 | tripped in olr | reset | 17:15:00 | 17:25:00 | |
| 19 | CHP | CC 223 | not healthy,cjd acted | informed operation | 21:30:00 | 21:55:00 | |
| 20 | WT | co 3 | zss acted,probe wire got cut | probe wire jointed | 14:30:00 | 14:40:00 | |
| 21 | WT | op1 | no movement @coupling,d6 olr acted | olr reset | 19:20:00 | 19:30:00 | |