



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 20/12/2025

Incharge(s): Saurabh Kumar Yadav

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------|---|-----------|----------|----------|---------|
| 1 | OHP | CO 111(b) | olr acted | reset | 15:30:00 | 15:35:00 | |
| 2 | OHP | co 46 | pc acted | reset | 14:50:00 | 14:55:00 | |
| 3 | OHP | TBS on CO 20 | Left B/C olr acted | reset | 18:30:00 | 18:45:00 | |
| 4 | OHP | VS 2A | OLR acted | reset | 20:32:00 | 20:40:00 | |
| 5 | OHP | CO 25 | OLR acted | reset | 20:40:00 | 20:50:00 | |
| 6 | CHP | CC 25 TT | position indication missing,loosed connection in i/o rack | tightened | 16:20:00 | 16:30:00 | |
| 7 | CHP | cc 45 | olr acted | reset | 16:30:00 | 16:40:00 | 2 times |
| 8 | CHP | CC 51 | mpd tripped | reset | 17:54:00 | 18:00:00 | |
| 9 | CHP | CC 54 | OLR acted | reset | 20:10:00 | 20:15:00 | |
| 10 | CHP | cc 58 | OLR acted | reset | 18:42:00 | 18:51:00 | 2 times |
| 11 | WT | OT 4 | D1 tripped in pgf1 fault | reset | 16:00:00 | 16:10:00 | |