



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/09/2025

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	olr acted	reset	07:00:00	07:10:00	
2	OHP	CO 24	olr acted	reset	11:40:00	11:45:00	
3	OHP	CO 87	BRS not healthy, BRs cable got cut near take up pulley	brs cable jointing done	12:15:00	12:40:00	
4	OHP	CO 58	not healthy ZSS acted, Probe wire got cut	re jointed	12:30:00	13:00:00	
5	OHP	TBS on CO 24	Rb/c not running, olr acted	reset	13:35:00	13:45:00	
6	CHP	CC 40 SCr3	slew not working, slew limit acted, jamming	informed operation	06:30:00	06:40:00	
7	CHP	CC 34 SCR 2	LT not taking place, OT acted	OT released	08:30:00	08:45:00	
8	CHP	CC 201 and 203	motor overload acted	reset	10:10:00	10:20:00	
9	CHP	CC 131	overload acted	reset	11:06:00	11:10:00	
10	CHP	CC 51	olr acted feeding conveyor stop	olr reset	12:20:00	12:25:00	
11	CHP	CC 28	olr acted	reset	07:25:00	07:30:00	