



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 12/11/2025

Shift: B

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO-28	Reported LT not working	checked and found drive tripped on earth fault.M4 removed and tested okay	19:40:00	19:54:00	M4 motor and cable to be checked
2	CHP	CC-23	Reported tripping	checked and found motor power cable got entangled with post and insulation damaged.Insulated properly and tested okay	15:00:00	15:30:00	
3	CHP	CC130 TIS	Reported not healthy	Checked and found EPB acted.Released and tested okay	14:30:00	14:40:00	
4	CHP	CC-132	Reported P/C acted	P/C switch reset done and tested okay	18:00:00	18:15:00	
5	CHP	CC-51	Reported BSS acted	Checked and found fuse burnt.Fuse replaced and BSS released and tested okay	15:15:00	15:30:00	
6	CHP	CC104 SCR-9	Reported Slew not taking place	OLR acted.Reset done	14:35:00	14:45:00	
7	CHP	CC 39 scr-2	LT not working	PCRD overtension acted.Released and tested okay	17:20:00	17:30:00	
8	CHP	Cc 105 SCR-10	Reported LT not taking place	Checked and found PCRD guide in full jamming condition	21:30:00	21:45:00	Informed to operation and mechanical
9	WT	OT-5	Reported tripped	Drive tripped due to jamming.(3 times).Reset done	14:15:00 19:35:00 19:50:00	14:20:00 19:40:00 19:55:00	