



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 29/04/2025

Shift: C

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 57	Pull chord not healthy	acted , reset done	23:30:00	23:50:00	
2	OHP	CO 35	OLR acted	reset done (3 times)	23:45:00	00:50:00	
3	OHP	BRC on CO 31	CT not moving	CT wheel on track , informed to operation	01:30:00	01:50:00	
4	OHP	WOBR on CO 29	Luff not working	Mechanical problem	02:00:00	02:20:00	
5	OHP	BRC on CO 8A	BW 2 not rotating	ZSS module problem , bypassed	03:40:00	04:00:00	
6	OHP	CO 25	BRS acting due to rain water	Bypassed in IO rack , operation request	03:40:00	03:50:00	
7	OHP	TIS on CO 29	ZSS bypassed	probe damaged	04:30:00	04:40:00	changing going on at shift ending
8	CHP	CC 104 , SCR 9	Slew not working	MPD tripped , reset done	02:30:00	02:50:00	
9	CHP	CC 34, SCR 2	BC signal missing	LT done towards tail end . Also PLC recycled 2 times	00:00:00	00:30:00	
10	CHP	CC 36 , SCR 1	BW not running	In operator cabin BW start button connection tightened	03:35:00	04:00:00	
11	CHP	CC 33, 40, 111,125,114	brs bypassed	operation requirement	03:05:00	04:15:00	again kept in circuit
12	CHP	CC 111	Drive end chute sensor acting due to rain	Bypassed	04:00:00	04:05:00	again kept in circuit



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 29/04/2025

Shift: C

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	CC 52	Stopped in ZSS	Due to overload on belt and tailend jamming. Informed to operation	01:45:00	01:55:00	
14	WT	OP 1	Not moving , overtravelled	Bus bar shorted , and reverse movement done	23:30:00	23:50:00	