



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 26/06/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|--------------------------------------------------------------|----------------------------------------------------------|----------|----------|------------------------------------|
| 1 | OHP | BRC ON CO8A | B/W S NOT RUNNING ZS PROBLEM | B/W 1 B/W 2 ZSS BYPASSED | 00:10:00 | 00:40:00 | DUE TO FESTOON CABLE PROBLEM |
| 2 | OHP | WOBR ON CO 26 | B/C STOPPING ON ZS CAGE STUCK UP WITH STONE | REMOVED | 02:20:00 | 02:40:00 | |
| 3 | OHP | CO 29 | OLR ACTED (3TIMES) | RESET | 03:05:00 | 04:05:00 | |
| 4 | OHP | BRC ON CO33M | B/W S NOT RUNNING | NO ELECTRICAL PROBLEM | 02:30:00 | 02:40:00 | |
| 5 | CHP | CC 54 | OLR ACTED(3TIMES) | RESET | 22:35:00 | 03:15:00 | |
| 6 | CHP | CC 117 | OLR ACTED(2TIMES) | RESET | 00:35:00 | 05:25:00 | |
| 7 | CHP | CC 39 SCR 7 | slew and B/W not running, return oil filter problem | return oil filter bypass as per operation and mechanical | 04:10:00 | 04:25:00 | mechanical will changed in A SHIFT |
| 8 | CHP | CC 131 | OLR ACTED | RESET | 01:10:00 | 01:15:00 | |
| 9 | CHP | cc 41 | motor not running, CJS acted due to jamming | informed operation | 04:10:00 | 04:20:00 | |
| 10 | WT | OP 9 | no movement, communication problem, signal strength bad 95db | pusher moved in local than ok | 01:50:00 | 02:15:00 | |
| 11 | WT | OC1A | OLR ACTED | RESET | 04:45:00 | 05:00:00 | DUE TO MATERIAL JAMMING |