



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 17/02/2026

Shift: C

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TT-1	Reported LT not taking place	MPCB tripped.Reset done(2 times)	23:30:00	00:00:00	
2	OHP	TT-1	Reported no power	MPCB tripped in LC-7.CRD cable stuck in roller and cable insulation damaged. rejoint done and tested okay	03:15:00	04:00:00	
3	OHP	TBS on CO-5A	LT not taking place	PCRD tension acted.Released and tested okay	03:55:00	04:15:00	
4	OHP	CO-34	Reported tripped	OLR acted.Reset done(2 times)	04:35:00	04:46:00	
5	CHP	Cc-51	MPD tripped	Reset done(2 times)	00:55:00	03:00:00	
6	CHP	CC-117	Reported tripped	OLR acted.Reset done	01:02:00	01:22:00	
7	CHP	CC-51	ZSS acting	Cage problem.Replaced and tested okay	22:45:00	23:15:00	
8	CHP	CC-37 SCR-3	ZSS acting	Cage stuck with coal.Replaced but pulse found missing.Bypassed to minimize GPL delay	22:25:00	22:35:00	Probe to be checked and to be replaced
9	CHP	Cc-218	CJD acted	Probe cleaned and tested okay	23:20:00	23:30:00	
10	CHP	Cc-32 S-3	Slewing not taking place	30 degree limit acted.	00:25:00	00:40:00	
11	CHP	Cc-104 SCR-7	LT not taking place	PCRD tension acted.Released and tested okay(4 times)	01:00:00	04:25:00	
12	CHP	Cc-216	CJD acted.	Probe cleaned and tested okay	01:45:00	01:55:00	
13	CHP	Cc-213	CJD acted.	Probe cleaned and tested okay	01:55:00	02:15:00	
14	CHP	CC-14	Control MCB tripped	CJB cable found loose and getting earthed.Tightened and tested okay	01:40:00	02:00:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/02/2026

Incharge(s): Amit Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
15	WT	OT-3	Tripped	D-1 tripped on Encoder-43 fault.Encoder cables at JB found damaged.Cable rejoint done and tested okay	23:40:00	00:40:00	