



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 16/10/2025

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	VS 2	OLR acted	reset	07:10:00	07:15:00	
2	OHP	BRC on co 8A	CT not working,drive tripped in OVN fault	reset	10:37:00	10:45:00	
3	OHP	rsco 10a	olr acted	reset	08:00:00	08:05:00	
4	OHP	TT2	chute vibrator mpcb tripped	made it on	12:00:00	12:10:00	
5	OHP	CO 33M	Lt not working,pcrd OT acted	released OT	11:30:00	11:45:00	
6	CHP	CC 51	OLR acted	reset	09:30:00	09:35:00	
7	CHP	CC 51	MPD trips 5 times	reset	09:00:00	12:55:00	
8	CHP	CC 37	LT not working,E PB acted	released	06:25:00	06:35:00	
9	CHP	CC 104 SCR9	all drive not running,main l/c tripped	acb made on	08:50:00	09:00:00	
10	CHP	cc 36 s1	pcrd cable fall down,pcrd gear box cable	INFORMED OPERATION AND MECHANICAL	12:20:00	12:45:00	
11	CHP	CC 37 SCR7	slew not working,spider break failed alarm	reset	10:30:00	10:41:00	
12	CHP	CC 105 SCR10	LT not working,OT acted	released	11:25:00	11:35:00	