



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 01/01/2026

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TT2	PCRD CABLE DRUM STUCK DUE TO PCRD CHAIN GOT CUT AND OLD JOINT OPENED	DRUM MADE FREE CABLE REJOINTED	20:30:00	21:30:00	
2	OHP	BRC ON CO 32	LT SKEW ACTED	INFORMED TO MECH	18:25:00	18:30:00	
3	OHP	CO 26	OLR ACTED	RESET	20:00:00	20:10:00	
4	CHP	CC 8 C/S ACTING	LOOSE CONNECTION IN MODULE	TIGHTENED	21:30:00	21:45:00	
5	CHP	CC 12	MCCB INTERLOCK LOOSE CONNECTION IN SLIDING CONTACTORS	TIGHTENED	18:00:00	18:15:00	
6	CHP	CC 203	OLR ACTED	RESET	18:10:00	18:20:00	
7	CHP	CC 51	FEEDING CONV MPD ACTED	RESET	15:00:00	21:30:00	3 TIMES
8	CHP	CC 117	OLR ACTED	RESET	21:25:00	21:40:00	
9	CHP	CC 132	OLR ACTED	RESET	15:25:00 16:05:00	15:30:00 16:10:00	
10	CHP	CC 54	OLR ACTED	RESET	14:40:00 15:00:00	14:50:00 15:05:00	
11	CHP	CC 51A	OLR ACTED	RESET	20:10:00	20:15:00	
12	CHP	CC 131	OLR ACTED	RESET	20:40:00	20:45:00	
13	WT	OP5	DRIVE 2 OLR ACTED	RESET	16:00:00	16:15:00	
14	WT	OT2	DRIVE 2 TRIPPED ON	RESET	20:50:00	20:55:00	