



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 01/08/2025

Shift: C

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO26	over load acted	Reset done	22:25:00	22:30:00	
2	OHP	TT3	Lt not taking place control fuse blown	replaced then ok	00:20:00	00:30:00	
3	OHP	CO33M	olr acted	Reset done	02:25:00	02:30:00	
4	OHP	BRC on CO31	No power found ACB off	made it on	23:15:00	23:30:00	
5	OHP	TT2	chute vibrator not working found MPCB trip	Made it on	23:40:00	23:50:00	
6	OHP	CO87	BRS bypassed as per operation request in I/O RACK	Bypassed at I/O rack	00:59:00	01:11:00	I/O list of CO 86 and CO 87 not available in LC 8
7	OHP	CO35a	BRS acting found common wire loose in module	Tightened then ok	23:07:00	23:25:00	
8	CHP	CC51	over load tripped	Reset done	02:55:00	03:00:00	
9	CHP	CC52	MPD tripped	Reset done	03:15:00	03:20:00	
10	CHP	CC52	over load trip	Reset done	03:20:00	03:25:00	
11	CHP	CC111	stopped due to BSS found Pull card acted	Reset done	22:50:00	23:00:00	
12	CHP	SCR2 on CC34	LT not working found over tension acted	Reset done	00:35:00	00:45:00	
13	CHP	S1 on Cc38	LT not working found LT drive over load tripped	Reset done	03:00:00	03:10:00	
14	CHP	CC35	BRS acting found electrical side ok	found ok informed to operation	04:25:00	04:30:00	
15	CHP	CC57	BRS bypassed as per operation requirement	again put in ckt as per operational request	04:55:00	05:00:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 01/08/2025

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
16	WT	OP2	D5 over load tripped	Reset done	04:00:00	04:20:00	
17	IOSA	NEW WOBR	B/W not running	OIL level level low.	02:00:00	02:10:00	Informed to mechanical