



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 12/01/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

| Sl No | Area | Equipment     | Problem                                     | Action                   | From                 | To                   | Remarks |
|-------|------|---------------|---|--------------------------|----------------------|----------------------|---------|
| 1     | OHP  | BRC on co 33m | CT not working,drive tripped                | reset                    | 16:50:00             | 17:00:00             |         |
| 2     | OHP  | CO 26         | cjd acted,fuse blown in TB                  | direct terminated        | 17:50:00             | 18:10:00             |         |
| 3     | CHP  | CC 44         | e pb contact problem                        | contact replaced         | 14:35:00             | 14:45:00             |         |
| 4     | CHP  | CC 39 SCr6    | LT not working,drive tripped                | reset                    | 16:05:00             | 16:15:00             |         |
| 5     | CHP  | CC 105 SCR10  | b/c not working,signal problem              | modem power recycle done | 15:50:00             | 16:10:00             |         |
| 6     | CHP  | CC 213        | conveyor stopped , CJS acted                | reset                    | 16:35:00             | 16:50:00             |         |
| 7     | CHP  | CC 103        | FLAP GATE MPCB TRIPPED                      | MADE IT ON               | 15:35:00             | 15:45:00             |         |
| 8     | CHP  | CC 51         | mpd acted 2 times                           | reset                    | 14:50:00             | 14:55:00             |         |
| 9     | CHP  | CC 54         | olr acted                                   | reset                    | 15:10:00             | 15:15:00             |         |
| 10    | WT   | OT3           | encoder fault, tripped 3 times              | reset                    | 17:20:00             | 17:25:00             |         |
| 11    | WT   | CO 4 (b)      | mpcb tripped                                | made on                  | 20:30:00             | 20:35:00             |         |
| 12    | WT   | OT 2          | PGF1 FAULT ACTED                            | RESET                    | 21:40:00             | 21:45:00             |         |
| 13    | IOSA | TBS           | communication problem,boom conveyor stopped | modem power recycled     | 18:20:00<br>20:35:00 | 18:35:00<br>20:55:00 |         |