



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/10/2025

Shift: B

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-77	TRIPPED ON OLR	RESET DONE	14:30:00	14:40:00	
2	OHP	BF-7A	REPORTED NOT HEALTHY E/STOP KNOB PROBLEM	E/STOP REPLACED WITH NEW THAN OK	17:15:00	17:30:00	
3	OHP	BRC ON CO-31	REPORTED B/C STOPPING FREQUANTELY CHECKED AND FOUND NO PROBLEM	NO LOAD CURRENT-16A LOAD CURRENT 18 TO 20A	21:40:00	22:10:00	
4	CHP	TT ON CC-103	REPORTED NO POWER CHECKED AND FOUND PCRD CABLE GOT CUT	PCRD CABLE RE JOINT DONE THAN OK	17:30:00	18:00:00	
5	CHP	CC-131	OLR ACTED	RESET DONE	18:30:00	18:35:00	
6	CHP	CC-54	OLR ACTED(3TIMES)	RESET DONE	16:10:00 19:30:00 19:45:00	16:15:00 19:35:00 19:50:00	
7	CHP	CC-111 S-3	REPORTED SIGNAL MISSING	LT TAKEN FORWARD DIRECTION THAN OK	15:10:00	15:25:00	
8	CHP	CC-104 SCR-9	REPORTED TUL C/S ACTED CHECKED AND FOUND JAMMING	JAMMING CLEARED THAN HEALTHY	15:15:00	15:30:00	
9	CHP	CC-34 SCR-2	LT NOT TAKING PLACE DRIVE TRIP	RESET DONE THAN OK	17:50:00	18:20:00	
10	CHP	CC-38 SCR-6	LT DRIVE TRIP DUE TO TRACK JAMMING	RESET DONE AND INFORM TO OPERATION	19:30:00 20:45:00	19:45:00 21:10:00	
11	CHP	CC-45	TRIPPED ON OLR	RESET DONE	18:10:00	18:20:00	
12	CHP	CC-104 SCR-9	TUL C/S ACTED FREQUANTELY	SENSOR PROBE ADJUSTED THAN OK	16:35:00	16:50:00	
13	WT	OC-1A	OLR ACTED	RESET DONE	14:45:00	14:55:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/10/2025

Incharge(s): K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	WT	OT-1	NOT MOVE FOUND DRIVE -1 TRIP PGF-1 FAULT	DRIVE-1 RESET DONE	15:45:00	15:55:00	
15	WT	OT-5	CD INDICATIONS MISSING CHECKED AND FOUND CONTROL SUPPLY PROBLEM	TEMPRARY SUPPLY PROVIDED	20:30:00	21:45:00	