



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 24/11/2025

Incharge(s): Amit Roy

Shift: C

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|------------------------------|--|----------------------|----------------------|---------|
| 1 | OHP | CO-14A | Reported BRS acted | Checked and reset done | 23:30:00 | 23:45:00 | |
| 2 | OHP | CO-33M | Reported tripped | OLR acted.Reset done | 22:56:00 | 23:05:00 | |
| 3 | OHP | CO-26 | Reported tripped | OLR acted.Reset done(2 times) | 03:50:00 | 04:00:00 | |
| 4 | OHP | CO-33S | Reported not running | Power recycled and tested okay | 02:40:00 | 02:50:00 | |
| 5 | OHP | BRC on CO-33M | Reported LT not taking place | Wrong complaint | 23:40:00 | 23:50:00 | |
| 6 | CHP | CC-38 SCR-6 | LT not working | M-2 tripped.Reset done | 22:28:00 | 22:40:00 | |
| 7 | CHP | CC-125 | Reported tripped | OLR acted.Reset done | 01:56:00 03:40:00 | 02:03:00 03:48:00 | |
| 8 | CHP | CC-39 SCR-2 | LT not working | PCRD OT acted.Released and tested okay(2times) | 02:17:00 03:29:00 | 02:30:00 03:41:00 | |
| 9 | CHP | Cc-39 SCR-2 | LT not working | Fuse burnt in I/O rack for PCRD command.Replaced and tested okay | 04:02:00 | 04:15:00 | |
| 10 | CHP | CC-33 SCR-5 | LT not working | PCRD OT limit acted.Reset done | 04:00:00 | 04:12:00 | |
| 11 | CHP | Cc-54 | Reported tripped | OLR acted.Reset done(4 times) | 00:30:00 | 05:50:00 | |
| 12 | CHP | RG-3 | FLap gate tripped | OLR acted.Reset done | 22:55:00 | 23:00:00 | |
| 13 | IOSA | BRC | Reported BW-1 not rotating | B/W stuck.Solenoid pressed released and tested okay | 01:30:00 | 01:45:00 | |