



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 25/01/2026

Incharge(s): Amit Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	Reported tripped	OLR acted.Reset done	06:30:00	06:35:00	
2	OHP	BRC on CO-8A	Reported B/C not running	OLR acted.Reset done	07:10:00	07:25:00	
3	OHP	TBS on CO-21	Reported LT not taking place	PCRD tension acted.Mechanical chain problem	10:30:00	10:45:00	Informed to mechanical
4	OHP	CO-6	ZSS acting	Probe cable cut.Rejoint done	11:00:00	11:15:00	
5	OHP	CO-7	Reported BRS not healthy	Checked and found JOD in acted condition.Reset done and tested okay	11:10:00	11:30:00	
6	CHP	CC-51	MPD acted	Feeding conveyor stopped.Reset done	06:00:00	11:00:00	
7	CHP	CC-107	BRS acting frequently	Due to coal dust	07:30:00	07:45:00	Informed to operation
8	CHP	CC-216	Reported tripped	OLR acted.Reset done	07:45:00	07:55:00	
9	CHP	CC-216	Reported C/S acted	Due to dust accumulation.probe cleaned and tested okay	08:35:00	08:45:00	
10	CHP	CC-213	C/S acted	Due to coal accumulation.	08:50:00	09:00:00	Informed to operation
11	WT	OT-4	Reported tripped	Drive-2 tripped on PGEF-4 fault.Reset done	11:50:00	11:55:00	