



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 02/07/2025

Area: WT

Equipment	Job
OP 10	Creepers along trolly line removed bottom side from col no 15 to 3
OC 1A	Area lighting problem rectified ,200W and 35W LEDs replaced
OP 1 and 4	after rake maintenance done