



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 13/05/2025

Area: IOSA

Equipment	Job
BRC	POWER CABLE LAYED FROM SHIPRING ASSEMBLY TO TRANSFORMER PRIMARY.
OC-17A	MOTOR PPM DONE.
WOBR (FLS)	BOOM CONVEYOR, BUCKET WHEEL PANEL MAINTENANCE AND CONTACTOR CHECKING DONE.