



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 12/05/2025

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO 32	B/C not running,olr acted	reset it	05:00:00	05:10:00	
2	OHP	CO 30 A	zss acted,probe damaged	probe replaced	23:30:00	23:45:00	
3	OHP	TBS on co 7A	LT not taking place,OT acted	OT released	05:10:00	05:20:00	
4	OHP	co 8A	BRS acted,sensor allignment problem	sensor adjusted	00:30:00	00:45:00	
5	CHP	CC 34 SCR 2	B/C not running	check and found all ok,wrong complaint	01:10:00	01:20:00	
6	CHP	CC 32 SCR 5	B/C not running,mpr trps in olr	reset it done	02:00:00	02:10:00	
7	CHP	CC 105 SCR 10	b/c not running,mpd trips due to coal jamming	reset it done and informed operation	04:30:00	04:40:00	