



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 21/10/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS on CO 7A	right boom(chp side) luff not taking place,drive trips in OBF fault continuously, drive keypad is not avialable	for reset drive power recycle done,luff up side ok.,control cable checked,drive all outgoing cable checked ,finally given position of boom manually	00:10:00	00:55:00	to be checked luff drive
2	OHP	CO 29	OLR acted	reset	01:00:00	01:10:00	
3	OHP	OC 1A(B)	OLR acted	reset	02:55:00	03:00:00	
4	CHP	CC 104 SCR 9	luffing not working,mpr tripped	reset	01:40:00	01:55:00	
5	CHP	CC 51	MPD tripped,stop feeding conveyor	reset	23:00:00	05:15:00	9 times
6	CHP	CC 51	OLR acted	reset	23:05:00	23:10:00	
7	CHP	CC 52	OLR acted	reset	00:25:00	00:30:00	
8	WT	OP 3	no movement,no power,bottom pad fallen,c clamp bend near col no 72	power block got @02.10 AM ,c clamp replaced,acb made on	01:45:00	02:55:00	
9	WT	CP 1	NOT moving,reverse direction,communication problem	modem power reset	23:30:00	23:45:00	no delay,after rake completion